

WATER WELL REPORT

STATE OF WASHINGTON

Application No.

Permit No.

33/01-13R

(1) OWNER: Name KRIEG CONST INC Address 4535 Hwy 20 OAK HARBOR
(2) LOCATION OF WELL: County ISLAND SE 1/4 SE 1/4 Sec 13 T 33 N, R 1E W.M.
Bearing and distance from section or subdivision corner

(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) 1
New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 114 1/2 ft. Depth of completed well 114 1/2 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 109 1/2 ft.
Threaded ☐ " Diam. from " ft. to " ft.
Welded ☒ " Diam. from " ft. to " ft.

Perforations: Yes ☐ No ☒
Type of perforator used _____
SIZE of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

Screens: Yes ☒ No ☐
Manufacturer's Name Johnson
Type WELDED Model No. 304
Diam. 6 Slot size 8 from 109 1/2 ft. to 114 1/2 ft.
Diam. _____ Slot size _____ from _____ ft. to _____ ft.

Gravel packed: Yes ☐ No ☒ Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

Surface seal: Yes ☒ No ☐ To what depth? 18 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(7) PUMP: Manufacturer's Name Gerold's
Type Sub H.P. 3/4

(8) WATER LEVELS: Land-surface elevation 150 ft.
Static level 94 ft. below top of well Date MAR 82
Artesian pressure _____ lbs. per square inch Date _____
Artesian water is controlled by _____ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☒ If yes, by whom? _____
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" " " " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test _____
Bailer test 10 gal./min. with 13 ft. drawdown after 4 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes ☐ No ☒

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
HARD GRAVEL	0	20
MOSTLY SAND	20	94
FINE WATER SAND	94	114
CLAY	114	

10 GPM

Work started MAR, 19 82, Completed MAR, 19 82

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WHIDBEY DRILLERS
(Person, firm, or corporation) (Type or print)

Address OAK HARBOR

[Signed] Pennin Fahn
(Well Driller)

License No. 129 Date MAR, 19 82